



Product Service

# CERTIFICATE

No. B 15 07 92685 002

**Holder of Certificate: Cixi Sinotech Solar Co., Ltd.**828#, Yongan Rd.  
315300 Cixi, Zhejiang  
PEOPLE'S REPUBLIC OF CHINA**Certification Mark:****Product:****Installation box  
Junction Box for PV Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

**Test report no.:** 704071511902-00**Valid until:** 2020-07-14**Date,** 2015-07-22  
( Yaqun Liu )

Page 1 of 2



Product Service

**CERTIFICATE**  
**No. B 15 07 92685 002**

**Model(s):** **ST605, ST606, ST609, ST612**

**Parameters:**

Rated Voltage:	1000VDC
Rated Current:	13A for ST605 (three diodes are in series) 13A for ST606 (three diodes are in series) 13A for ST609 (three diodes are in series) 8A for ST612 (two diodes are in series)
Reverse Current:	25A for ST605, ST606 and ST609 15A for ST612
Application Class:	A
Protection Class:	II
Degree of Protection:	IP67 for ST605, ST606 and ST609 IP65 for ST612
Ambient Temperature:	-40°C~+85°C

**Tested according to:** EN 50548:2011/A1:2013

**Production Facility(ies):** 92685