



Product Service

CERTIFICATE

No. B 092685 0004 Rev. 02

Holder of Certificate: Cixi Sinwo Solar Technology Co.,Ltd.

Dianqiao Village ,Changhe Town
315326 Cixi City,Ningbo, Zhejiang
PEOPLE'S REPUBLIC OF CHINA

Production 092685

Facility(ies):

Certification Mark:



Product: Connector

Connectors for Photovoltaic Systems

Model(s): ST4, ST5, ST6

Parameters:

Rated Voltage:	1500VDC
Rated Current:	30A for ST4, ST5 15A or 30A for ST6
Application Class	A
Protection Class:	II
Degree of Protection:	IP68(1m,1h)
Ambient Temperature:	-40°C ~ +85°C

Tested according to: IEC 62852(ed.1)
EN 62852:2015

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704071511903-03

Valid until: 2025-06-17

Date, 2020-06-18

(Yaqu Alex Liu)