



Product Service

# CERTIFICATE

No. B 092685 0003 Rev. 03

**Holder of Certificate:** Cixi Sinwo Solar Technology Co.,Ltd.

Dianqiao Village ,Changhe Town  
315326 Cixi City,Ningbo, Zhejiang  
PEOPLE'S REPUBLIC OF CHINA

**Production Facility(ies):** 092685

**Certification Mark:**



**Product:** Installation box

Junction Box for PV Module

**Model(s):** ST605, ST606, ST608,ST609,ST616,ST619

**Parameters:**

Rated Voltage:	1500VDC
Rated Current:	15A (three diodes are in series)
Reverse Current:	25A
Application Class:	A
Protection Class:	II
Degree of Protection:	IP68(1m,1h)
Ambient Temperature:	-40°C ~ +85°C

**Tested according to:** IEC 62790(ed.1)  
EN 62790:2015

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 704071511902-04

**Valid until:** 2025-06-17

**Date,** 2020-06-18

( Yaqun Alex Liu )